

Dear Customer:

Here is a list of past power interruptions and their cause. We here at Oakville Hydro are sorry for any inconveniences they have caused.
This file was last updated: Tuesday, January 31, 2012 at 3:42:50 PM

Date: January 31, 2012

Area of Town: East-West Borders: Sixth Line to Ninth Line
North-South Borders: Dundas St to Leighland Ave

Outage Cause: A cement pump truck contacted the 27,600 volt line with its boom causing a large flash which in turn caused the breaker to trip.

Outage Time: From 2:45pm to 2:50pm

Date: January 31, 2012

Area of Town: East-West Borders: Sixth Line to Winston Churchill
North-South Borders: Dundas St to Sheridan Gardens

Outage Cause: Defective high voltage underground primary cable.

Outage Time: From 12:07pm to 2:03pm

Date: January 27, 2012

Area of Town: East-West Borders: Maple Grove Dr to Kerr St
North-South Borders: Cornwall Rd to Lake Ontario

Outage Cause: A squirrel came into contact with a high voltage wire causing the breaker to trip.

Outage Time: From 12:09am to 12:11am

Date: January 23, 2012

Streets Involved: Burnhamthorpe Rd

Outage Cause: A switch on a high voltage transformer went defective and had to be replaced.

Outage Time: From 8:22pm to 11:00pm

Date: January 22, 2012

Area of Town: East-West Borders: Maple Grove Dr to Kerr St
North-South Borders: Cornwall Rd to Lake Ontario

Outage Cause: Unknown at this time, a full patrol to take place on Monday morning.

Outage Time: From 12:04 for a few seconds

Date: January 19, 2012

Streets Involved: Cornwall Rd

Outage Cause: A fuse on a high voltage transformer went defective and had to be replaced.

Outage Time: From 7:28am to 9:00am

Date: January 13, 2012

Streets Involved: Duncan Rd

Outage Cause: All the connections on a high voltage transformer went defective and had to be replaced.

Outage Time: From 5:30pm to 6:30pm

Date: January 13, 2012

Streets Involved: Pine Cliff Rd and Oakhaven Dr

Outage Cause: A high voltage transformer was hit by a vehicle totally destroying it. The transformer had to be replaced.

Outage Time: From 10:10am to 12:40pm

Date: January 13, 2012

Streets Involved: Trafalgar Rd

Outage Cause: A high voltage transformer went defective and had to be replaced.

Outage Time: From 7:45am to 12:05pm

Date: January 6, 2012

Streets Involved: Ennisclare Dr

Outage Cause: A schedule interruption to allow for the replacement of a voltage transformer.

Outage Time: From 9:00am to 10:30 am

Date: January 5, 2012

Streets Involved: Linbrook Rd

Outage Cause: A high voltage transformer was replaced.